

## **COAX CABLE**



## TITLE:

Low Loss Coax Direct Burial

#### CODE:

SFX/125-DB-GRN-250


### **DESCRIPTION:**

250m SFX125 Coaxial Direct Burial Green PΕ

## SUPPLIED AS:

Reel of 250m

- High frequency, low loss cable, designed to carry CCTV, TV and Satellite Signals
- Manufactured with gas injected foam granting the cable a much better mechanical, electrical and ageing performance compared to a solid PE dielectric
- High density polyethelyne is the most environmentally stable plastic
- This family of cable contains both a foil and braided screen, enhancing performance and reducing interference
- An outdoor rated cable designed to be buried under ground wthout a need for conduit or ducting

















enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23













# **Product Specification**



#### **Cable Construction**

CPR	Fca
Conductor Diameter (mm)	1.25 ±0.01
Inner Conductor	Bare Copper
Overall Diameter (mm)	9.50 ±0.20
Compliance and Standards	CE2014/30/EU,RoHS2 2011/65/EU,LVD 2014/35/EU

#### Insulation

Insulation	Foamed PE	
Insulation Colour	White	
Insulation Thickness (mm)	1.18 ±0.01	

## **Outer/Jacket Specification**

Outer Jacket	PE
Outer Jacket Colour	Green RAL 6016
Inner Jacket	PE
Inner Jacket Colour	Green RAL 6016
Inner Jacket Diameter (mm)	8.00 ±0.20
Inner Jacket Thickness (mm)	1.05 ±0.10
Overall Colour	Green
Overall Diameter (mm)	9.50 ±0.20
Jacket Colour	Green RAL 6016

### **Electrical Characteristics**

Outer Conductor DC resistance @ 20°C	<45O/km
Rated Temperature (°C)	-20°C to 80°C
Impedance	75O ±3O
Capacitance	>52 nF/km
























## **COAX CABLE**



## **MORE INFORMATION:**

EURO	CLASSIFICATION CRITERIA							
CLASS FIRE SFX COMMENT		CPR GUIDE Securi-Flex						
Reaction to Fire BS EN ISO 1716			SUBCLASSIFICATIONS FOR EUROCLASSES Boa to Doa					
A <sub>ca</sub>	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.		SMOKE RODUCTION		D) FLAMING DROPLETS		A) SMOKE CIDITY
Reaction to Fire BS EN 50399		BS EN 50399/BS EN 61034-2		BS EN 50399		BS EN 60754-2		
B1 <sub>ca</sub>	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.		s1a: s1 + transmittance >=80% (BS EN 61034-2)		d0: No fall of droplets or flaming particles, times for 1200 seconds		a1: Very low acidity (conductivity <2.5 uS/mm & pH >4.3)
B2 <sub>ca</sub>	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.		s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)		d1: Fall of droplets or		a2: low acidity
Cca	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.		s1: Low production of slow propagation of smoke  s2: Intermediate production & propagation		flaming particles that persist for less than 10 seconds, timed for 1200 seconds		(conductivity <10 µS/mm & pH >4.3)
D <sub>ca</sub>	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.		of smoke s3: None of the above		d2: None of the above	l	d2: None of the above
Reaction to Fir	e BS EN 60332-1-2						_	
E <sub>ca</sub>	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 KW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.		Visit us onlin www.securiflex			K	The Trusted Cable Brand
F <sub>ca</sub>	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	M Fo	lasses A to E have to be tested lost cables will fall into classes or a cable to meet Aca, B1ca, I ctory audits.	B2	2ca to Eca.		,

## **OUR OPERATING TEMPERATURE RANGE GUIDE**











enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23











