ALARM CABLE



TITLE:

Alarm Type 2 Copper Direct Burial

CODE:

SFX/12C-TY2-SCR-DB-PE-BLK-1


DESCRIPTION:

1m (per metre) 12 Core Type 2 Alarm Screened Direct Burial Black HDPE

SUPPLIED AS:

Per 1m Lengths

- Generally used for connecting alarm equipment such as sensors, control panels and other low voltage circuits
- This cable is ROHS compliant
- High density polyethelyne is the most environmentally stable plastic
- A premium alarm cable conforming to BS4737
- An outdoor rated cable designed to be buried under ground wthout a need for conduit or ducting

































ALARM CABLE



Product Specification



Cable Construction

Cable Construction	12 Cores
CPR	Fca
Conductor	Tinned Copper
Conductor Diameter (mm)	0.19 ±0.008 x 7
Stranded Diameter (mm)	0.22
Overall Diameter (mm)	6.00 ±0.200
Compliance and Standards	BS4737-3.30:2015,RoHS2 2011/65/EU

Insulation

Insulation	PVC
Insulation Colour	Red, Black, Blue, Yellow, Green, White, Orange, Brown, Turquoise, Pink, Violet, Greynge, Green, White, Orange, Green, White
Insulation Resistance @20°C	>200 MO/km
Insulation Thickness (mm)	0.21

Outer/Jacket Specification

Outer Jacket	HDPE
Outer Jacket Colour	Black RAL 9005
Inner Jacket	HDPE
Inner Jacket Colour	Black RAL 9005
Inner Jacket Diameter (mm)	6.00 ±0.100
Inner Jacket Thickness (mm)	0.6
Overall Colour	Black
Overall Diameter (mm)	6.00 ±0.200
Jacket Colour	Black RAL 9005
Nylon Rip-Cord	Red 210D

Electrical Characteristics

Insulation Resistance @20°C	>200 MO/km
Max Conductor DC resistance @ 20°C	100O/km
Rated Temperature (°C)	-20°C to 80°C
Rated Voltage (V)	30V
























S ALARM CABLE



MORE INFORMATION:

EURO	CLASSIFICATION CRITERIA							
CLASS FIRE SFX COMMENT			(CPR GUII	E Sec	;L	uri-Flex	
Reaction to Fir	e BS EN ISO 1716		s	UBCLASSIFICATIONS	3 F	FOR EUROCLASSES	3 E	Sca to Dca
A _{ca}	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.		SMOKE RODUCTION		D) FLAMING DROPLETS		A) SMOKE CIDITY
Reaction to Fire BS EN 50399		BS	BS EN 50399/BS EN 61034-2		BS EN 50399		BS EN 60754-2	
B1 _{ca}	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)			d0: No fall of droplets or flaming particles, times for 1200 seconds		a1: Very low acidity (conductivity <2.5 uS/mm & pH >4.3)
B2 _{ca}	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1: LC propa s2: In produ of sm	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)		d1: Fall of droplets or		a2: low acidity
Cca	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.		s1: Low production of slow propagation of smoke s2: Intermediate		flaming particles that persist for less than 10 seconds, timed for 1200 seconds		(conductivity <10 µS/mm & pH >4.3)
D _{ca}	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.		production & propagation of smoke s3: None of the above		d2: None of the above		d2: None of the above
Reaction to Fir	e BS EN 60332-1-2						0	
E _{ca}	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 KW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.		Visit us onlin www.securiflex			K	The Trusted Cable Brand
F _{ca}	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	Classes A to E have to be tested by an independent authorised laboratory. Most cables will fall into classes B2ca to Eca. For a cable to meet Aca, B1ca, B2ca or Cca, there also needs to be regular on-going factory audits.					*

OUR OPERATING TEMPERATURE RANGE GUIDE











enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23









