

**TITLE:**

Alarm TCCA Type 3 Screened LSF

**CODE:**

SFX/8C-TY3-SCR-LSF-WHT-200



**DESCRIPTION:**

200m 8 Core TCCA Type 3 Alarm  
Screened White LSF

**SUPPLIED AS:**

Reel of 200m

- Generally used for connecting alarm equipment such as sensors, control panels and other low voltage circuits
- This cable is ROHS compliant
- Low smoke and fume plastic is good for use inside public buildings and spaces as will not emit toxic gases if the cable catches fire
- This is the most popular and cost effective cable for general intruder alarm solutions
- Improved performance and protection against fire



enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23



# Product Specification

25-YEAR WARRANTY



## Cable Construction

Cable Construction	8 Cores
CPR	Eca
Conductor	Tinned Copper Clad Aluminium
Conductor Diameter (mm)	0.20 ±0.008 x 7
Stranded Diameter (mm)	0.22
Overall Diameter (mm)	4.60 ±0.200
Compliance and Standards	BS4737-3.30:2015, RoHS2 2011/65/EU

## Insulation

Insulation	PVC
Insulation Colour	Red, Black, Blue, Yellow, Green, White, Orange, Brown
Insulation Resistance @20°C	>200 MO/km
Insulation Thickness (mm)	0.21

## Outer/Jacket Specification

Jacket	LSF
Overall Colour	White
Overall Diameter (mm)	4.60 ±0.200
Jacket Colour	White RAL 9003
Jacket Thickness (mm)	0.5
Nylon Rip-Cord	Yellow 210D

## Electrical Characteristics

Insulation Resistance @20°C	>200 MO/km
Max Conductor DC resistance @ 20°C	155Ω/km
Rated Temperature (°C)	-20°C to 80°C
Rated Voltage (V)	30V



enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23




## MORE INFORMATION:

CPR replaced the Construction Products Directive and was incorporated into UK law following Brexit. It determines the harmonised rules for all construction products and gives a common technical language for the performance of all construction products. It is mandatory for a manufacturer to apply the CE mark to their products together with the Euroclass rating (CPR classification). Eca Euroclass and above requires 3rd party testing by a notified body (CE), and approved body (UKCA). CPR has been in place since the 1st of July 2017 and it will be mandatory for manufacturers to apply the UKCA mark to all products after the 31st of December 2025 for sale in the UK

EURO CLASS (ca:cable)	CLASSIFICATION CRITERIA		CPR GUIDE		
	FIRE RATING	SFX COMMENT	Securi-Flex®		
Reaction to Fire BS EN ISO 1716			SUBCLASSIFICATIONS FOR EUROCLASSES Bca to Dca		
<b>A<sub>ca</sub></b>	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.	<b>(S) SMOKE PRODUCTION</b>	<b>(D) FLAMING DROPLETS</b>	<b>(A) SMOKE ACIDITY</b>
Reaction to Fire BS EN 50399			BS EN 50399/BS EN 61034-2	BS EN 50399	BS EN 60754-2
<b>B1<sub>ca</sub></b>	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)	d0: No fall of droplets or flaming particles, times for 1200 seconds	a1: Very low acidity (conductivity <2.5 µS/mm & pH >4.3)
<b>B2<sub>ca</sub></b>	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)	d1: Fall of droplets or flaming particles that persist for less than 10 seconds, timed for 1200 seconds	a2: low acidity (conductivity <10 µS/mm & pH >4.3)
<b>C<sub>ca</sub></b>	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.	s1: Low production of slow propagation of smoke		
<b>D<sub>ca</sub></b>	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.	s2: Intermediate production & propagation of smoke	d2: None of the above	d2: None of the above
Reaction to Fire BS EN 60332-1-2			Visit us online: <a href="http://www.securiflex.co.uk">www.securiflex.co.uk</a>		
<b>E<sub>ca</sub></b>	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 KW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.	<b>SFX®</b> The Trusted Cable Brand		
<b>F<sub>ca</sub></b>	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	Classes A to E have to be tested by an independent authorised laboratory. Most cables will fall into classes B2ca to Eca. For a cable to meet Aca, B1ca, B2ca or Cca, there also needs to be regular on-going factory audits.		

## OUR OPERATING TEMPERATURE RANGE GUIDE



Securi-Flex®

enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23