
TELECOM CABLE







Product Specification



Cable Construction

Cable Construction	10 Pairs
CPR	Eca
Conductor	Bare Copper
Conductor Diameter (mm)	0.40 ±0.008
Overall Diameter (mm)	7.00 ±0.20
Insulation	
Insulation	PVC
Insulation Colour White/Blue,Blue/White,White/Orange,Orange/White,White/Green,Green/White,White	te/Brown,Brown/White,White/Grey,Grey/White,Red/Blue,Blue/Red,Red/Orange,Orange,Red,Red/Green,Green/Red,Red/Grey,Grey,Red,Black/Blue,Blue,Blue,Black/
Insulation Resistance @20°C	>200MO/km
Insulation Thickness (mm)	0.185
Outer/Jacket Specification	
Jacket	LSF
Overall Colour	White
Overall Diameter (mm)	7.00 ±0.20
Jacket Colour	White RAL 9003
Jacket Thickness (mm)	0.45
Nylon Rip-Cord	210D
Electrical Characteristics	
Insulation Resistance @20°C	>200MO/km
Max Conductor DC resistance @ 20°C	<1200/km
Rated Temperature (°C)	-20°C to 80°C
Rated Voltage (V)	30V

Telecom cable

enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23

TERMS AND CONDITIONS APPLY - WHILE EVERY EFFORT HAS BEEN MADE TO ENSURE THE ACCURACY AND COMPLETENESS OF THE INFORMATION, NO GUARANTEE IS GIVEN NOR RESPONSIBILITY TAKEN FOR ERRORS OR OMISSIONS IN THIS DATA SHEET. FLÖME-FLEX Drum-ROll LUCKINS Opin Extension Basec * KNX @ 🧱 🐇



EURO	CLASS	FICATION CRITERIA			
CLASS (ca:cable)		SFX COMMENT	CPR GUI	DE Sec	curi-Flex
Reaction to F	ire BS EN ISO 1716		SUBCLASSIFICATIONS	S FOR EUROCLASSES	S Bca to Dca
A _{ca}	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.		DROPLETS	(A) SMOKE
	ire BS EN 50399	be specified with extreme caution.	BS EN 50399/BS EN 61034-2	BS EN 50399	BS EN 60754-2
B1 _{ca}	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)	d0: No fall of droplets or flaming particles, times for 1200 seconds	a1: Very low ac (conductivity <2 µS/mm & pH >4
82.a	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)	d1: Fall of droplets or	a2: low acidity
Coa	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.	s1: Low production of slow propagation of smoke s2: Intermediate	flaming particles that persist for less than 10 seconds, timed for 1200 seconds	(conductivity <1 µS/mm & pH >4
D _{ca}	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.	production & propagation of smoke s3: None of the above	d2: None of the above	d2: None of the above
Reaction to F	ire BS EN 60332-1-2	nie growania measured.	_	_	_
E _{ca}	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 KW pre-mixed flame. Note: This test does not measure heat release. toxic fumes or smoke.	Visit us onlin www.securiflex		The Truste Cable Brai
F _{ca}	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	Classes A to E have to be teste Most cables will fall into classes For a cable to meet Aca, B1ca, factory audits.	B2ca to Eca	,
			GUIDE		
		200° —	SILICONE		
		90° —	HRPVC		
		80°	PE & PVC		
		70°			
		70°			
		70 ° 	LSZH 		
		70°	LSZH		
		70°	PE,PVC &		
		70°	LSZH 		
		70°	LSZH		
		70°	LSZH 		
		70°	LSZH		

enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23

TERMS AND CONDITIONS APPLY - WHILE EVERY EFFORT HAS BEEN MADE TO ENSURE THE ACCURACY AND COMPLETENESS OF THE INFORMATION, NO GUARANTEE IS GIVEN NOR RESPONSIBILITY TAKEN FOR ERRORS OF OMISSIONS IN THIS DATA SHEET.

FLÖME-FLEX Drum-ROll LUCKINS Opin Extension Basec * KNX @ 🧱 🐇