

TELECOM CABLE



TITLE:

CW1308 LSF

CODE:

SFX/CW1308-6-LSF-WHT-200


DESCRIPTION:

200m CW1308 6 Pair White LSF

SUPPLIED AS:

Reel of 200m

- Manufactured to British Telecom specification and generally used for internal connections
- Popular in the security industry for door entry systems where voice is required
- Low smoke and fume plastic is good for use inside public buildings and spaces as will not emit toxic gases if the cable catches fire
- Can also be used for low level signal applications
- Improved performance and protection against fire
- Good for low cost fixed instillations



























enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23



TELECOM CABLE



Product Specification (CP







Cable Construction

Cable Construction	6 Pairs
CPR	Eca
Conductor	Bare Copper
Conductor Diameter (mm)	0.40 ±0.008
Overall Diameter (mm)	5.00 ±0.20

Insulation

Insulation	PVC
Insulation Colour White/Blue,Blue/White,White/Orange,Orange/White,Whi	te/Green,Green/White,White/Brown,Brown/White,White/Grey,Grey/White,Red/Blue,Blue/Red
Insulation Resistance @20°C	>200MO/km
Insulation Thickness (mm)	0.185

Outer/Jacket Specification

Jacket	LSF	
Overall Colour	White	
Overall Diameter (mm)	5.00 ±0.20	
Jacket Colour	White RAL 9003	
Jacket Thickness (mm)	0.45	
Nylon Rip-Cord	210D	

Electrical Characteristics

Insulation Resistance @20°C	>200MO/km
Max Conductor DC resistance @ 20°C	<1200/km
Rated Temperature (°C)	-20°C to 80°C
Rated Voltage (V)	30V
























TELECOM CABLE



MORE INFORMATION:

EURO	CLASSIFICATION CRITERIA				
CLASS (ca:cable)	FIRE RATING	SFX COMMENT	CPR GUII	DE <i>Se</i> c	curi-Flex°
Reaction to Fire BS EN ISO 1716 SUBCLASSIFICATIONS FOR EUROCLASSES Bca to Dca					
A _{ca}	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.	(S) SMOKE PRODUCTION	(D) FLAMING DROPLETS	(A) SMOKE ACIDITY
Reaction to Fir	e BS EN 50399		BS EN 50399/BS EN 61034-2	BS EN 50399	BS EN 60754-2
B1 _{ca}	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)	d0: No fall of droplets or flaming particles, times for 1200 seconds	a1: Very low acidity (conductivity <2.5 uS/mm & pH >4.3)
B2 _{ca}	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)	d1: Fall of droplets or	a2: low acidity
Cea	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.	s1: Low production of slow propagation of smoke s2: Intermediate	flaming particles that persist for less than 10 seconds, timed for 1200 seconds	(conductivity <10 µS/mm & pH >4.3)
D _{ca}	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.	production & propagation of smoke s3: None of the above	d2: None of the above	d2: None of the above
Reaction to Fir	e BS EN 60332-1-2				
E _{ca}	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 kW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.	Visit us onlin www.securiflex		The Trusted Cable Brand
F _{ca}	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	Classes A to E have to be tested by an independent authorised laboratory. Most cables will fall into classes B2ca to Eca. For a cable to meet Aca, B1ca, B2ca or Cca, there also needs to be regular on-going factory audits.		

OUR OPERATING TEMPERATURE RANGE GUIDE











enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23











