



## TITLE:

FR120 Fire Enhanced Flame-Flex

## CODE:

SFX/FC-2C-4.0-FR120-ENH-RED-500



## DESCRIPTION:

500m FR120 2 Core 4.0mm 300/500V  
Red Enhanced FLAME-FLEX 120

## SUPPLIED AS:

Reel of 500m

- Can be used both internally and externally in environments where suitable protection is present
- Polymer tape comes away from the sheath when stripping cable
- Low smoke zero halogen plastic is good for use inside public buildings and spaces as will not emit toxic gases if the cable catches fire
- High resistance to kinks to protect cables performance
- Suitable for installations where a circuit must be maintained for up to 120 minutes in the event of a fire
- Can be cut to any length required up to 500m to reduce installation times



enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23



## Product Specification

25-YEAR WARRANTY



### Cable Construction

Cable Construction	2 Cores
CPR	LPCB
Conductor	Solid Bare Copper
Overall Diameter (mm)	12.6 ±0.2

### Insulation

Insulation	Mica tape covered by extruded LSZH
Insulation Colour	Blue,Brown
Insulation Thickness (mm)	0.90 ±0.02

### Outer/Jacket Specification

Jacket	UV LSZH
Overall Colour	Red
Overall Diameter (mm)	12.6 ±0.2
Jacket Colour	Red RAL 3000
Jacket Thickness (mm)	1.10 ±0.01

### Electrical Characteristics

Rated Temperature (°C)	-30° to +70°
Rated Voltage (V)	300/500V



enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23



# FIRE CABLE



Fire cable

## MORE INFORMATION:

www.redbooklive.com

**Certificate of Product Approval**

Certificate Number: 1569a (d-1) Issue: 01

**Securi-Flex Limited**

Mackley Ind. Estate  
Henfield Road  
Small Dole  
Henfield  
BN5 9XR

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

**Product(s)**

Cable Types as listed below:  
SPX Fire Resistant Cable

**Standard(s) (see Appendix for details)**

BS 7629-1:2015 Enhanced 120  
BS 6387:2013 (Category CW2)  
BS 5839-1:2013 (Clause 26.2c Enhanced)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd. **Obada Piracha** 30 June 2021 30 June 2021  
Certification Manager Date of Issue Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/conditions](http://www.redbooklive.com/conditions))  
To check the validity of this certificate and appendix please visit [www.redbooklive.com/verify](http://www.redbooklive.com/verify) with the QR tag or contact us:  
BRE Global Ltd, Garsington Road, Oxford, OX4 1JF  
T: +44 (0)1865 191 881 F: [enquiries@bre.co.uk](mailto:enquiries@bre.co.uk)  
LPCB® is a registered trademark of the Building Research Establishment Ltd.

BF1345 Rev 2.3 Page 1 of 2 © BRE Global Ltd, 2021



enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23

TERMS AND CONDITIONS APPLY - WHILE EVERY EFFORT HAS BEEN MADE TO ENSURE THE ACCURACY AND COMPLETENESS OF THE INFORMATION, NO GUARANTEE IS GIVEN NOR RESPONSIBILITY TAKEN FOR ERRORS OR OMISSIONS IN THIS DATA SHEET.

