

BELDEN QUIVALENTS



TITLE:

ISP Individual Foil Screen PE

CODE:

SFX/ISP2-SWA-PE-BLK-1


DESCRIPTION:

1m (per metre) ISP2 2pr 22AWG Individual Foil Screen 600V SWA Black PE (8723)

SUPPLIED AS:

Per 1m Lengths

- Wideley used in the security industry for CCTV telemetry purposes
- Also used in appliactions such as computing where extra screening is required to prevent cross talk between pairs
- Polyethylene plastic is excellent for use externally above ground or below ground inside ducting
- Provides mechanical protection against cable being pinched or pierced
- **UV** resistant

































BELDEN EQUIVALENTS



Product Specification



Cable Construction

Cable Construction	2 Pairs
CPR	Fca
Conductor	Tinned Copper
Conductor Diameter (mm)	0.24 ±0.008 x 7(0.33mm²)
Stranded Diameter (mm)	0.64
Overall Diameter (mm)	8.00 ±0.20

Insulation

Insulation	HDPE	
Insulation Colour	Red,Black;Green,White	
Insulation Resistance @20°C	>200MO/km	
Insulation Thickness (mm)	0.28	

Outer/Jacket Specification

Outer Jacket	PE
Outer Jacket Colour	Black RAL 9005
Inner Jacket	PE
Inner Jacket Colour	Black RAL 9005
Inner Jacket Thickness (mm)	0.55
Overall Colour	Black
Overall Diameter (mm)	8.00 ±0.20
Jacket Colour	Black RAL 9005
Nylon Rip-Cord	White 210D

Electrical Characteristics

Insulation Resistance @20°C	>200MO/km
M 0 1 1 PO 1-1 0 0000	4500 Hz.
Max Conductor DC resistance @ 20°C	<56O/km
Detect Terrer ereture (80)	20% 4- 20%
Rated Temperature (°C)	-20°C to 80°C
Detect Material AA	0001
Rated Voltage (V)	600V









enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23
















BELDEN EQUIVALENTS



MORE INFORMATION:

EURO	CLASSIFICATION CRITERIA				
CLASS (ca:cable)	FIRE RATING	SFX COMMENT	CPR GUII	DE <i>Sec</i>	curi-Flex®
Reaction to Fir	e BS EN ISO 1716		SUBCLASSIFICATIONS FOR EUROCLASSES Bca to Dca		
A _{ca}	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.	(S) SMOKE PRODUCTION	(D) FLAMING DROPLETS	(A) SMOKE ACIDITY
Reaction to Fir	e BS EN 50399		BS EN 50399/BS EN 61034-2	BS EN 50399	BS EN 60754-2
B1 _{ca}	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)	d0: No fall of droplets or flaming particles, times for 1200 seconds	a1: Very low acidity (conductivity <2.5 µS/mm & pH >4.3)
B2 _{ca}	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)	d1: Fall of droplets or	a2: low acidity
Cca	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.	s1: Low production of slow propagation of smoke s2: Intermediate	flaming particles that persist for less than 10 seconds, timed for 1200 seconds	(conductivity <10 μS/mm & pH >4.3)
D _{ca}	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.	production & propagation of smoke s3: None of the above	d2: None of the above	d2: None of the above
Reaction to Fir	e BS EN 60332-1-2				
E _{ca}	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 kW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.	Visit us onlin www.securiflex		The Trusted Cable Brand
F _{ca}	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.	Classes A to E have to be tested by an independent authorised laboratory. Most cables will fall into classes B2ca to Eca. For a cable to meet Aca, B1ca, B2ca or Cca, there also needs to be regular on-going factory audits.		

OUR OPERATING TEMPERATURE RANGE GUIDE











enquiries@securiflex.co.uk | www.securiflex.co.uk | 03333 44 66 23









